

September 5, 2008

JAY R. SMITH MFG. CO
CHRIS LEVINS
2781 GUNTER PARK DR
MONTGOMERY AL 36109

Re: Description: VALVE, BACKWATER
Manufacturer: JAY R. SMITH MFG. CO
Product Name: FLOOD-GATE
Model Number(s): 7140Y04 and 7140Y06
Product File No: 20080471

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of December 2013.

This approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in an accessible ventilated area.
- Model 7140Y04 must be installed in a horizontal drain line that is at least 9 inches below the fixture outlets to which it is protecting.
- Model 7140Y06 must be installed in a horizontal drain line that is at least 14 inches below the fixture outlets to which it is protecting.

This approval supersedes the approval issued on December 18 2003 under product file number 20030514

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20030514.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jerry Thompson
Plumbing Product Reviewer
Phone: 608-266-6742
Fax: 608-267-9566
E-mail: Jerry.Thompson@wi.gov